

階	柱番号	柱位置		出隅柱		横架材の上端間(垂直距離)		計算式				H階	記号	接合金物		判定
		X	Y	階数1又は 階数2の2階	階数2の 1階	H1 (m)	H2 (m)	X方向	Y方向	N階	柱脚			柱頭		
1階	2	X4	Y0	○	○	2.700	2.700	(2.50x0.80)x2.7/2.7+(0.00x0.80)x2.7/2.7-1.00	1.00	(2.50x0.80)x2.7/2.7+(2.50x0.80)x2.7/2.7-1.00	3.00	3.00	ち	ち/4	ち/4	OK
1階	3	X5	Y0	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	-1.60	い	い/	い/	OK
1階	4	X6	Y0	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60	-0.35	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	-0.35	ち#	ち#/N	ち#/N	OK
1階	5	X7	Y0	×	×	2.700	2.700	(2.50x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60	0.90	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	0.90	は	は/T	は/T	OK
1階	7	X4	Y1	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	(2.50x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60 [X4Y2] (2.50x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	0.90 -0.35	0.90	は	は/T	は/T	OK
1階	8	X8	Y1	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	(2.50x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60	0.90	0.90	は	は/T	は/T	OK
1階	11	X8	Y2	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60 [X7Y2] (0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60 -1.60	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	-1.60	い	い/	い/	OK
1階	14	X8	Y3	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	-1.60	い	い/	い/	OK
1階	16	X0	Y4	○	○	2.700	2.700	(0.00x0.80)x2.7/2.7+(0.00x0.80)x2.7/2.7-1.00	-1.00	(2.50x0.80)x2.7/2.7+(0.00x0.80)x2.7/2.7-1.00	1.00	1.00	は	は/T	は/T	OK
1階	17	X2	Y4	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60	-0.35	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	-0.35	ち#	ち#/N	ち#/N	OK
1階	18	X3	Y4	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60	-0.35	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	-0.35	ち#	ち#/N	ち#/N	OK
1階	22	X8	Y4	×	×	2.700	2.700	(2.50x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60 [X7Y4] (2.50x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60	0.90 0.90	(2.50x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60	0.90	0.90	は	は/T	は/T	OK
1階	23	X9	Y4	×	—	2.700	—	(0.00x0.50)x2.7/2.7-0.60	-0.60	(0.00x0.50)x2.7/2.7-0.60	-0.60	-0.60	い	い/	い/	OK
1階	24	X10	Y4	×	—	2.700	—	(2.50x0.50)x2.7/2.7-0.60	0.65	(0.00x0.50)x2.7/2.7-0.60	-0.60	0.65	ろ	ろ/N	ろ/N	OK
1階	27	X0	Y5	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	-1.60	い	い/	い/	OK
1階	30	X9	Y5	×	—	2.700	—	(0.00x0.50)x2.7/2.7-0.60	-0.60	(2.50x0.50)x2.7/2.7-0.60	0.65	0.65	ろ	ろ/N	ろ/N	OK
1階	32	X10	Y5.5	×	—	2.700	—	(0.00x0.50)x2.7/2.7-0.60	-0.60	(2.50x0.50)x2.7/2.7-0.60	0.65	0.65	ろ	ろ/N	ろ/N	OK
1階	33	X12	Y5.5	×	—	2.700	—	(0.00x0.50)x2.7/2.7-0.60	-0.60	(2.50x0.50)x2.7/2.7-0.60	0.65	0.65	ろ	ろ/N	ろ/N	OK
1階	34	X0	Y6	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	-1.60	い	い/	い/	OK
1階	38	X9	Y6	×	—	2.700	—	(0.00x0.50)x2.7/2.7-0.60 [X8Y6] (0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-0.60	-0.60 -0.60	(2.50x0.50)x2.7/2.7-0.60	0.65	0.65	ろ	ろ/N	ろ/N	OK
1階	39	X10	Y6.5	×	—	2.700	—	(0.00x0.50)x2.7/2.7-0.60	-0.60	(2.50x0.50)x2.7/2.7-0.60	0.65	0.65	ろ	ろ/N	ろ/N	OK
1階	40	X12	Y6.5	×	—	2.700	—	(0.00x0.50)x2.7/2.7-0.60	-0.60	(0.00x0.50)x2.7/2.7-0.60	-0.60	-0.60	い	い/	い/	OK
1階	41	X0	Y7	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60 [X1Y7] (0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60 -1.60	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	-1.60	い	い/	い/	OK
1階	48	X12	Y7.5	○	—	2.700	—	(0.00x0.80)x2.7/2.7-0.40	-0.40	(2.50x0.80)x2.7/2.7-0.40	1.60	1.60	ほ	ほ/Pe	ほ/Pe	OK
1階	49	X0	Y8	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	(0.00x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60	-0.35	-0.35	ち#	ち#/N	ち#/N	OK
1階	51	X2	Y8	×	×	2.700	2.700	(2.50x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-0.35	(0.00x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60 [X2Y7] (0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-0.35 -1.60	-0.35	ち#	ち#/N	ち#/N	OK
1階	52	X3	Y8	×	×	2.700	2.700	(2.50x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-0.35	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60 [X3Y7] (0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60 -1.60	-0.35	い	い/	い/	OK
1階	57	X8	Y8	×	×	2.700	2.700	(2.50x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-0.35	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60 [X8Y7] (0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60 -1.60	-0.35	い	い/	い/	OK
1階	58	X9	Y8	×	—	2.700	—	(2.50x0.50)x2.7/2.7-0.60	0.65	(0.00x0.50)x2.7/2.7-0.60	-0.60	0.65	ろ	ろ/N	ろ/N	OK
1階	61	X0	Y9	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	-1.60	い	い/	い/	OK
1階	62	X2	Y9	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	(0.00x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60	-0.35	-0.35	ち#	ち#/N	ち#/N	OK
1階	65	X8	Y9	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	(0.00x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60	-0.35	-0.35	ち#	ち#/N	ち#/N	OK
1階	66	X10	Y9	×	—	2.700	—	(0.00x0.50)x2.7/2.7-0.60	-0.60	(2.50x0.50)x2.7/2.7-0.60	0.65	0.65	ろ	ろ/N	ろ/N	OK
1階	69	X0	Y10	○	○	2.700	2.700	(2.50x0.80)x2.7/2.7+(0.00x0.80)x2.7/2.7-1.00	1.00	(2.50x0.80)x2.7/2.7+(2.50x0.80)x2.7/2.7-1.00	0.00	0.00	ち	ち/4	ち/4	OK
1階	70	X1	Y10	—	×	2.700	—	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	-1.60	い	い/	い/	OK
1階	71	X2	Y10	×	×	2.700	2.700	(2.50x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60	0.90	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	0.90	は	は/T	は/T	OK
1階	72	X3	Y10	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60	-0.35	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	-0.35	ち#	ち#/N	ち#/N	OK
1階	76	X7	Y10	×	×	2.700	2.700	(0.00x0.50)x2.7/2.7+(2.50x0.50)x2.7/2.7-1.60	-0.35	(0.00x0.50)x2.7/2.7+(0.00x0.50)x2.7/2.7-1.60	-1.60	-0.35	ち#	ち#/N	ち#/N	OK
1階	77	X8	Y10	○	×	2.700	2.700	(2.50x0.50)x2.7/2.7+(2.50x0.80)x2.7/2.7-1.60	1.65	(0.00x0.50)x2.7/2.7+(2.50x0.80)x2.7/2.7-1.60	0.40	1.65	へ	へ/2	へ/2	OK
1階	78	X9	Y10	×	—	2.700	—	(0.00x0.50)x2.7/2.7-0.60	-0.60	(0.00x0.50)x2.7/2.7-0.60	-0.60	-0.60	い	い/	い/	OK
1階	79	X10	Y10	○	—	2.700	—	(2.50x0.80)x2.7/2.7-0.40	1.60	(2.50x0.80)x2.7/2.7-0.40	1.60	1.60	ほ	ほ/Pe	ほ/Pe	OK
2階	2	X4	Y0	○	—	—	2.700	(0.00x0.80)x2.7/2.7-0.40	-0.40	(2.50x0.80)x2.7/2.7-0.40	1.60	1.60	ほ	ち\$/4\$	ほ/Pe	OK
2階	4	X6	Y0	×	—	—	2.700	(2.50x0.50)x2.7/2.7-0.60	0.65	(0.00x0.50)x2.7/2.7-0.60	-0.60	0.65	ろ	ろ/N	ろ/N	OK
2階	5	X7	Y0	×	—	—	2.700	(2.50x0.50)x2.7/2.7-0.60	0.65	(0.00x0.50)x2.7/2.7-0.60	-0.60	0.65	ろ	ろ/N	ろ/N	OK
2階	7	X4	Y1	×	—	—	2.700	(0.00x0.50)x2.7/2.7-0.60	-0.60	(2.50x0.50)x2.7/2.7-0.60	0.65	0.65	ろ	ろ/N	ろ/N	OK
2階	8	X8	Y1	×	—	—	2.700	(0.00x0.50)x2.7/2.7-0.60	-0.60	(2.50x0.50)x2.7/2.7-0.60	0.65	0.65	ろ	ろ/N	ろ/N	OK
2階	11	X8	Y2	×	—	—	2.700	(0.00x0.50)x2.7/2.7-0.60	-0.60	(0.00x0.50)x2.7/2.7-0.60	-0.60	-0.60	い	い/	い/	OK
2階	14	X8	Y3	×	—	—	2.700	(0.00x0.50)x2.7/2.7-0.60	-0.60	(0.00x0.50)x2.7/2.7-0.60	-0.60	-0.60	い	い/	い/	OK
2階	17	X2	Y4	×	—	—	2.700	(2.50x0.50)x2.7								